



A photograph of a retail store ceiling. The ceiling is made of white acoustic tiles. Several large, silver, flexible ducts are exposed and run across the ceiling. A central circular vent is visible. Track lighting is installed on the ceiling. In the background, clothing racks and store displays are visible.

Hur täta är våra
ventilations-
kanaler?

Täthetsklasser enligt svensk och europeisk standard





Rätt material

Tätt?

Montage



Tätt

AMA YTC.157
Kontroll av
luftbehandlings-
system

10 %


20 %

av kanalsystemens area
ska täthetskontrolleras.


Hur mycket luft läcker?

1 meter


Läckflöde/Kanalflöde, Ø1000 mm, 100 Pa



Läckflöde/Kanalflöde, Ø125 mm, 300 Pa



Osynliga fel sänker lätt täthetsklassen







Täta kanaler

S material

S montage

S mätning